

板坂地区

(放流水質)

令和7年度

月	pH	SS mg/l	COD mg/l		BOD mg/l	Cl ⁻ mg/l	T-N mg/l		T-P mg/l		大腸菌数 CFU/ml
排水基準値	5.8- 8.6	90 (70)	50 (40)		25 (20)		120 (60)		16 (8)		800
4	7.4	7.0	26.0	27.0	11.0	30.0	28.0	28.0	3.20	3.40	1未満
5	7.4	4.0	24.0	28.0	11.0	30.0	26.0	25.0	2.90	3.20	1未満
6											
7											
8											
9											
10											
11											
12											
1											
2											
3											
平均	7.4	5.5		26.3	11.0	30.0		26.8		3.18	1.0
最大	7.4	7.0		28.0	11.0	30.0		28.0		3.40	1.0
最小	7.4	4.0		24.0	11	30.0		25.0		2.90	1.0

板坂地区

(流入水質)

月	pH	SS mg/l	COD mg/l	BOD mg/l	T-N mg/l	T-P mg/l
5	7.0	160.0	100.0	130.0	39.0	4.1
8						
11						
2						
平均	7.0	160.0	100.0	130.0	39.0	4.1
最大	7.0	160.0	100.0	130.0	39.0	4.1
最小	7.0	160.0	100.0	130.0	39.0	4.1

放流基準値

pH	5.8以上8.6以下	—
SS	50以下	mg/l
COD	40以下	mg/l
BOD	20以下	mg/l
Cl ⁻	—	mg/l
T-N	60以下	mg/l
T-P	8以下	mg/l
大腸菌数	800以下	CFU/ml

鍛冶屋地区 (放流水質)

令和7年度

月	pH	SS mg/l	COD mg/l				BOD mg/l	Cl ⁻ mg/l	T-N mg/l				T-P mg/l				大腸菌数 CFU/ml
排水基準値	5.8-8.6	90 (70)	50 (40)				25 (20)		120 (60)				16 (8)				800
4	7.4	3.0	30.0	29.0	31.0	29.0	10.0	36.0	32.0	32.0	31.0	29.0	3.30	3.10	3.20	3.00	1未満
5	7.4	3.0	27.0	26.0	27.0	25.0	12.0	36.0	30.0	28.0	29.0	28.0	3.10	2.90	3.20	3.00	1未満
6																	
7																	
8																	
9																	
10																	
11																	
12																	
1																	
2																	
3																	
平均	7.4	3.0				28.0	11.0	36.0	29.9				3.10				1.0
最大	7.4	3.0				31.0	12.0	36.0	32.0				3.30				1.0
最小	7.4	3.0				25.0	10.0	36.0	28.0				2.90				1.0

鍛冶屋地区 (流入水質)

月	pH	SS mg/l	COD mg/l	BOD mg/l	T-N mg/l	T-P mg/l
5	7.0	190.0	130.0	180.0	41.0	4.2
8						
11						
2						
平均	7.0	190.0	130.0	180.0	41.0	4.2
最大	7.0	190.0	130.0	180.0	41.0	4.2
最小	7.0	190.0	130.0	180.0	41.0	4.2

放流基準値		
pH	5.8以上8.6以下	—
SS	50以下	mg/l
COD	40以下	mg/l
BOD	20以下	mg/l
Cl ⁻	—	mg/l
T-N	60以下	mg/l
T-P	8以下	mg/l
大腸菌数	800以下	CFU/ml

余田地区

(放流水質)

令和7年度

月	pH	SS mg/l	COD mg/l				BOD mg/l	Cl ⁻ mg/l	T-N mg/l				T-P mg/l				大腸菌数 CFU/ml
排水基準値	5.8- 8.6	90 (70)	50 (40)				25 (20)		120 (60)				16 (8)				800
4	7.3	4.0	30.0	28.0	30.0	24.0	14.0	35.0	30.0	30.0	31.0	24.0	3.50	3.20	3.50	3.00	1未満
5	7.2	5.0	22.0	22.0	21.0	20.0	7.7	29.0	24.0	21.0	22.0	20.0	2.70	2.40	2.50	2.40	1未満
6																	
7																	
8																	
9																	
10																	
11																	
12																	
1																	
2																	
3																	
平均	7.3	4.5				24.6	10.9	32.0	25.3				2.90				1.0
最大	7.3	5.0				30.0	14.0	35.0	31.0				3.50				1.0
最小	7.2	4.0				20.0	7.7	29.0	20.0				2.40				1.0

余田地区

(流入水質)

月	pH	SS mg/l	COD mg/l	BOD mg/l	T-N mg/l	T-P mg/l
5	7.1	130.0	110.0	120.0	38.0	3.9
8						
11						
2						
平均	7.1	130.0	110.0	120.0	38.0	3.9
最大	7.1	130.0	110.0	120.0	38.0	3.9
最小	7.1	130.0	110.0	120.0	38.0	3.9

放流基準値		
pH	5.8以上8.6以下	—
SS	50以下	mg/l
COD	40以下	mg/l
BOD	20以下	mg/l
Cl ⁻	—	mg/l
T-N	60以下	mg/l
T-P	8以下	mg/l
大腸菌数	800以下	CFU/ml

大貫地区

(放流水質)

令和7年度

月	pH	SS mg/l	COD mg/l				BOD mg/l	Cl ⁻ mg/l	T-N mg/l				T-P mg/l				大腸菌数 CFU/ml
排水基準値	5.8-8.6	90 (70)	50 (40)				25 (20)		120 (60)				16 (8)				800
4	7.4	3.0	21.0	20.0	22.0	20.0	10.0	31.0	27.0	25.0	26.0	21.0	2.80	2.90	3.10	2.90	1未満
5	7.1	3.0	20.0	19.0	21.0	20.0	7.3	27.0	22.0	20.0	21.0	19.0	2.90	2.80	3.00	2.60	1未満
6																	
7																	
8																	
9																	
10																	
11																	
12																	
1																	
2																	
3																	
平均	7.3	3.0				20.4	8.7	29.0				22.6				2.88	1.0
最大	7.4	3.0				22.0	10.0	31.0				27.0				3.10	1.0
最小	7.1	3.0				19.0	7.3	27.0				19.0				2.60	1.0

大貫地区

(流入水質)

月	pH	SS mg/l	COD mg/l	BOD mg/l	T-N mg/l	T-P mg/l
5	6.9	130.0	110.0	130.0	42.0	4.1
8						
11						
2						
平均	6.9	130.0	110.0	130.0	42.0	4.1
最大	6.9	130.0	110.0	130.0	42.0	4.1
最小	6.9	130.0	110.0	130.0	42.0	4.1

放流基準値		
pH	5.8以上8.6以下	—
SS	50以下	mg/l
COD	40以下	mg/l
BOD	20以下	mg/l
Cl ⁻	—	mg/l
T-N	60以下	mg/l
T-P	8以下	mg/l
大腸菌数	800以下	CFU/ml

田口地区

(放流水質)

令和7年度

月	pH	SS mg/l	COD mg/l		BOD mg/l	Cl ⁻ mg/l	T-N mg/l		T-P mg/l		大腸菌数 CFU/ml
排水基準値	5.8-	90	50		25		120		16		800
	8.6	(70)	(40)		(20)		(60)		(8)		
4	6.6	4.0	8.9	8.5	1.4	33.0	1.7	1.8	2.50	2.60	1
5	6.5	4.0	8.1	7.8	2.1	32.0	1.7	1.7	2.60	3.00	1未満
6											
7											
8											
9											
10											
11											
12											
1											
2											
3											
平均	6.6	4.0		8.3	1.8	32.5		1.7		2.68	1.0
最大	6.6	4.0		8.9	2.1	33.0		1.8		3.00	1.0
最小	6.5	4.0		7.8	1.4	32.0		1.7		2.50	1.0

田口地区

(流入水質)

月	pH	SS mg/l	COD mg/l	BOD mg/l	T-N mg/l	T-P mg/l
5	7.2	190	130.0	170.0	43.0	5.0
8						
11						
2						
平均	7.2	190	130.0	170.0	43.0	5.0
最大	7.2	190	130.0	170.0	43.0	5.0
最小	7.2	190	130.0	170.0	43.0	5.0

放流基準値		
pH	5.8以上8.6以下	—
SS	50以下	mg/l
COD	40以下	mg/l
BOD	20以下	mg/l
Cl ⁻	—	mg/l
T-N	60以下	mg/l
T-P	8以下	mg/l
大腸菌数	800以下	CFU/ml

八千種地区

(放流水質)

令和7年度

月	pH	SS mg/l	COD mg/l				BOD mg/l	Cl ⁻ mg/l	T-N mg/l				T-P mg/l				大腸菌数 CFU/ml
排水基準 値	5.8- 8.6	90 (70)	50 (40)				25 (20)		120 (60)				16 (8)				800
4	6.6	4.0	7.5	6.0	6.1	7.1	0.6	37.0	1.1	1.4	0.9	1.0	2.10	2.20	2.00	1.90	1未満
5	6.7	4.0	6.0	6.9	6.2	6.3	1.6	36.0	0.8	1.1	1.0	0.9	1.70	1.60	2.00	1.90	1未満
6																	
7																	
8																	
9																	
10																	
11																	
12																	
1																	
2																	
3																	
平均	6.7	4.0				6.5	1.1	36.5				1.0				1.93	1.0
最大	6.7	4.0				7.5	1.6	37.0				1.4				2.20	1.0
最小	6.6	4.0				6.0	0.6	36.0				0.8				1.60	1.0

八千種地区

(流入水質)

月	pH	SS mg/l	COD mg/l	BOD mg/l	T-N mg/l	T-P mg/l
5	7.0	60.0	73.0	91.0	37.0	3.5
8						
11						
2						
平均	7.0	60.0	73.0	91.0	37.0	3.5
最大	7.0	60.0	73.0	91.0	37.0	3.5
最小	7.0	60.0	73.0	91.0	37.0	3.5

放流基準値		
pH	5.8以上8.6以下	—
SS	50以下	mg/l
COD	40以下	mg/l
BOD	20以下	mg/l
Cl ⁻	—	mg/l
T-N	60以下	mg/l
T-P	8以下	mg/l
大腸菌数	800以下	CFU/ml