

板坂地区

(放流水質)

令和8年度

月	pH	SS mg/l	COD mg/l		BOD mg/l	Cl ⁻ mg/l	T-N mg/l		T-P mg/l		大腸菌数 CFU/ml
排水基準値	5.8- 8.6	90 (70)	50 (40)		25 (20)		120 (60)		16 (8)		800
4	7.4	2.0	24.0	20.0	5.2	27.0	22.0	26.0	2.60	3.20	1未満
5	7.5	5.0	23.0	26.0	7.8	26.0	27.0	35.0	3.10	4.00	1未満
6	7.1	6.0	21.0	20.0	4.3	23.0	29.0	32.0	3.00	3.10	1未満
7											
8											
9											
10											
11											
12											
1											
2											
3											
平均	7.3	4.3		22.3	5.8	25.3		28.5		3.17	1.0
最大	7.5	6.0		26.0	7.8	27.0		35.0		4.00	1.0
最小	7.1	2.0		20.0	4.3	23.0		22.0		2.60	1.0

板坂地区

(流入水質)

月	pH	SS mg/l	COD mg/l	BOD mg/l	T-N mg/l	T-P mg/l
5	7.1	160.0	92.0	110.0	42.0	3.7
8						
11						
2						
平均	7.1	160.0	92.0	110.0	42.0	3.7
最大	7.1	160.0	92.0	110.0	42.0	3.7
最小	7.1	160.0	92.0	110.0	42.0	3.7

放流基準値

	放流基準値	
pH	5.8以上8.6以下	—
SS	50以下	mg/l
COD	40以下	mg/l
BOD	20以下	mg/l
Cl ⁻	—	mg/l
T-N	60以下	mg/l
T-P	8以下	mg/l
大腸菌数	800以下	CFU/ml

鍛冶屋地区 (放流水質) 令和8年度

月	pH	SS mg/l	COD mg/l				BOD mg/l	Cl ⁻ mg/l	T-N mg/l				T-P mg/l				大腸菌数 CFU/ml
排水基準値	5.8-8.6	90 (70)	50 (40)				25 (20)		120 (60)				16 (8)				800
4	7.4	1.0	24.0	22.0	25.0	23.0	5.8	30.0	25.0	25.0	27.0	26.0	2.60	2.80	2.90	2.70	1未満
5	7.6	4.0	25.0	26.0	25.0	24.0	9.4	32.0	30.0	29.0	30.0	28.0	3.00	3.30	3.40	3.20	1未満
6	7.4	2.0	25.0	19.0	22.0	22.0	6.9	32.0	29.0	22.0	27.0	26.0	3.20	2.50	4.00	2.80	1未満
7																	
8																	
9																	
10																	
11																	
12																	
1																	
2																	
3																	
平均	7.5	2.3				23.5	7.4	31.3	27.0				3.03				1.0
最大	7.6	4.0				26.0	9.4	32.0	30.0				4.00				1.0
最小	7.4	1.0				19.0	5.8	30.0	22.0				2.50				1.0

鍛冶屋地区 (流入水質)

月	pH	SS mg/l	COD mg/l	BOD mg/l	T-N mg/l	T-P mg/l
5	7.1	200.0	120.0	160.0	48.0	4.8
8						
11						
2						
平均	7.1	200.0	120.0	160.0	48.0	4.8
最大	7.1	200.0	120.0	160.0	48.0	4.8
最小	7.1	200.0	120.0	160.0	48.0	4.8

放流基準値		
pH	5.8以上8.6以下	—
SS	50以下	mg/l
COD	40以下	mg/l
BOD	20以下	mg/l
Cl ⁻	—	mg/l
T-N	60以下	mg/l
T-P	8以下	mg/l
大腸菌数	800以下	CFU/ml

余田地区

(放流水質)

令和8年度

月	pH	SS mg/l	COD mg/l				BOD mg/l	Cl ⁻ mg/l	T-N mg/l				T-P mg/l				大腸菌数 CFU/ml
排水基準値	5.8- 8.6	90 (70)	50 (40)				25 (20)		120 (60)				16 (8)				800
4	7.2	2.0	19.0	20.0	24.0	22.0	1.6	20.0	17.0	19.0	24.0	21.0	1.70	2.00	2.60	2.10	1未満
5	7.5	6.0	23.0	24.0	25.0	21.0	6.8	28.0	27.0	27.0	30.0	25.0	2.80	2.90	3.40	2.80	1未満
6	7.3	4.0	20.0	14.0	19.0	16.0	7.4	28.0	26.0	16.0	24.0	18.0	2.80	1.70	3.60	2.00	1未満
7																	
8																	
9																	
10																	
11																	
12																	
1																	
2																	
3																	
平均	7.3	4.0				20.6	5.3	25.3	22.8				2.53				1.0
最大	7.5	6.0				25.0	7.4	28.0	30.0				3.60				1.0
最小	7.2	2.0				14.0	1.6	20.0	16.0				1.70				1.0

余田地区

(流入水質)

月	pH	SS mg/l	COD mg/l	BOD mg/l	T-N mg/l	T-P mg/l
5	7.2	120.0	87.0	110.0	38.0	4.0
8						
11						
2						
平均	7.2	120.0	87.0	110.0	38.0	4.0
最大	7.2	120.0	87.0	110.0	38.0	4.0
最小	7.2	120.0	87.0	110.0	38.0	4.0

放流基準値		
pH	5.8以上8.6以下	—
SS	50以下	mg/l
COD	40以下	mg/l
BOD	20以下	mg/l
Cl ⁻	—	mg/l
T-N	60以下	mg/l
T-P	8以下	mg/l
大腸菌数	800以下	CFU/ml

大貫地区

(放流水質)

令和8年度

月	pH	SS mg/l	COD mg/l				BOD mg/l	Cl ⁻ mg/l	T-N mg/l				T-P mg/l				大腸菌数 CFU/ml
排水基準値	5.8-8.6	90 (70)	50 (40)				25 (20)		120 (60)				16 (8)				800
4	7.2	2.0	18.0	19.0	21.0	20.0	12.0	24.0	17.0	17.0	19.0	17.0	2.20	2.30	2.80	2.30	1未満
5	7.3	4.0	21.0	22.0	26.0	23.0	4.8	26.0	20.0	21.0	22.0	18.0	2.70	3.00	3.30	2.90	1未満
6	7.0	4.0	24.0	18.0	21.0	19.0	8.7	29.0	17.0	14.0	15.0	13.0	2.90	2.10	3.70	2.30	1未満
7																	
8																	
9																	
10																	
11																	
12																	
1																	
2																	
3																	
平均	7.2	3.3				21.0	8.5	26.3				17.5				2.71	1.0
最大	7.3	4.0				26.0	12.0	29.0				22.0				3.70	1.0
最小	7	2.0				18.0	4.8	24.0				13.0				2.10	1.0

大貫地区

(流入水質)

月	pH	SS mg/l	COD mg/l	BOD mg/l	T-N mg/l	T-P mg/l
5	7.1	36.0	45.0	58.0	30.0	2.9
8						
11						
2						
平均	7.1	36.0	45.0	58.0	30.0	2.9
最大	7.1	36.0	45.0	58.0	30.0	2.9
最小	7.1	36.0	45.0	58.0	30.0	2.9

放流基準値		
pH	5.8以上8.6以下	—
SS	50以下	mg/l
COD	40以下	mg/l
BOD	20以下	mg/l
Cl ⁻	—	mg/l
T-N	60以下	mg/l
T-P	8以下	mg/l
大腸菌数	800以下	CFU/ml

田口地区

(放流水質)

令和8年度

月	pH	SS mg/l	COD mg/l		BOD mg/l	Cl ⁻ mg/l	T-N mg/l		T-P mg/l		大腸菌数 CFU/ml
排水基準値	5.8-	90	50		25		120		16		800
	8.6	(70)	(40)		(20)		(60)		(8)		
4	6.5	2.0	8.0	11.0	1.4	28.0	1.4	2.0	2.50	3.10	1未満
5	6.8	3.0	9.0	9.1	1.0	32.0	2.0	1.8	2.80	2.90	1未満
6	6.6	13.0	9.5	9.1	5.4	29.0	1.8	12.0	2.40	4.20	1未満
7											
8											
9											
10											
11											
12											
1											
2											
3											
平均	6.6	6.0		9.3	2.6	29.7		3.5		2.98	1.0
最大	6.8	13.0		11.0	5.4	32.0		12.0		4.20	1.0
最小	6.5	2.0		8.0	1.0	28.0		1.4		2.40	1.0

田口地区

(流入水質)

月	pH	SS mg/l	COD mg/l	BOD mg/l	T-N mg/l	T-P mg/l
5	7.2	65	61.0	86.0	40.0	3.6
8						
11						
2						
平均	7.2	65	61.0	86.0	40.0	3.6
最大	7.2	65	61.0	86.0	40.0	3.6
最小	7.2	65	61.0	86.0	40.0	3.6

放流基準値		
pH	5.8以上8.6以下	—
SS	50以下	mg/l
COD	40以下	mg/l
BOD	20以下	mg/l
Cl ⁻	—	mg/l
T-N	60以下	mg/l
T-P	8以下	mg/l
大腸菌数	800以下	CFU/ml

八千種地区

(放流水質)

令和8年度

月	pH	SS mg/l	COD mg/l				BOD mg/l	Cl ⁻ mg/l	T-N mg/l				T-P mg/l				大腸菌数 CFU/ml
排水基準 値	5.8- 8.6	90 (70)	50 (40)				25 (20)		120 (60)				16 (8)				800
4	6.6	6.0	7.4	7.3	8.1	7.6	1.9	28.0	2.2	24.0	2.4	3.7	2.00	5.10	1.20	2.30	1未満
5	6.6	7.0	6.9	7.5	7.6	7.2	1.8	33.0	7.0	6.9	6.3	7.6	2.30	2.70	2.70	2.50	1未満
6	6.4	5.0	6.3	6.1	5.9	7.3	1.4	34.0	8.1	10.0	11.0	9.0	2.50	1.90	3.20	2.40	1未満
7																	
8																	
9																	
10																	
11																	
12																	
1																	
2																	
3																	
平均	6.5	6.0				7.1	1.7	31.7				8.2				2.57	1.0
最大	6.6	7.0				8.1	1.9	34.0				24.0				5.10	1.0
最小	6.4	5.0				5.9	1.4	28.0				2.2				1.20	1.0

八千種地区

(流入水質)

月	pH	SS mg/l	COD mg/l	BOD mg/l	T-N mg/l	T-P mg/l
5	7.2	77.0	76.0	95.0	44.0	3.9
8						
11						
2						
平均	7.2	77.0	76.0	95.0	44.0	3.9
最大	7.2	77.0	76.0	95.0	44.0	3.9
最小	7.2	77.0	76.0	95.0	44.0	3.9

放流基準値		
pH	5.8以上8.6以下	—
SS	50以下	mg/l
COD	40以下	mg/l
BOD	20以下	mg/l
Cl ⁻	—	mg/l
T-N	60以下	mg/l
T-P	8以下	mg/l
大腸菌数	800以下	CFU/ml